



Sample image

C80

Type Size: S2

Classification Contact: Rigid contact bridge

Classification Contact Mat: Silver

Classification Terminal: Screw terminal

IEC 60947-3 EN 60947-3, VDE 0660 Teil 107

Rated insulation voltage Ui

| Voltage (V) | AC / DC |
|-------------|---------|
| 690 | AC / DC |

Rated impulse withstand voltage Uimp

| Voltage (kV) | Overtoltage category | Pollution degree | Supply system | Function |
|--------------|----------------------|------------------|--|------------------------------|
| 6 | III | 3 | Valid for lines with grounded common neutral termination | Switch / Switch disconnecter |

Rated uninterrupted current Iu/Ith

| Current (A) | Ambient temperature (°C) | Peak temperature (°C) | additional requirements |
|-------------|--------------------------|-----------------------|--|
| 115 | 55 | 60 | Ambient temperature +55°C during 24 hours with peaks up to +60°C |

Conventional enclosed thermal current Ithe

| Current (A) | Ambient temperature (°C) | Peak temperature (°C) | Additional requirements | No. of stages (from - to) | Mounting | Mounting size |
|-------------|--------------------------|-----------------------|--|---------------------------|----------|---------------|
| 115 | 35 | 40 | Ambient temperature +35°C during 24 hours with peaks up to +40°C | -- | -- | -- |

Rated operational current Ie

| Utilization category | Voltage (V) | Current (A) |
|----------------------|-------------|-------------|
| AC-13 | 230 | 50 |
| AC-20A | 690 | 115 |
| AC-21A | 20 - 690 | 100 |
| AC-22A | 220 - 500 | 100 |
| AC-22A | 660 - 690 | 100 |

Rated operational power

| Utilization category | Voltage (V) | No. of phases | No. of poles | Power (kW) |
|----------------------|-------------|---------------|--------------|------------|
| AC-2 | 220 - 240 | 3 | 3 | 30 |
| AC-2 | 380 - 440 | 3 | 3 | 45 |
| AC-2 | 500 - 500 | 3 | 3 | 55 |
| AC-2 | 660 - 690 | 3 | 3 | 55 |
| AC-3 | 220 - 240 | 3 | 3 | 15 |
| AC-3 | 380 - 440 | 3 | 3 | 30 |
| AC-3 | 500 - 500 | 3 | 3 | 30 |
| AC-3 | 660 - 690 | 3 | 3 | 30 |
| AC-3 | 110 - 120 | 1 | 2 | 3,70 |
| AC-3 | 220 - 240 | 1 | 2 | 7,50 |
| AC-3 | 380 - 440 | 1 | 2 | 13 |
| AC-4 | 220 - 240 | 3 | 3 | 6 |
| AC-4 | 380 - 440 | 3 | 3 | 11 |
| AC-4 | 500 - 500 | 3 | 3 | 11 |
| AC-4 | 660 - 690 | 3 | 3 | 11 |
| AC-4 | 110 - 120 | 1 | 2 | 1,50 |
| AC-4 | 220 - 240 | 1 | 2 | 3 |
| AC-4 | 380 - 440 | 1 | 2 | 5,50 |
| AC-23A | 220 - 240 | 3 | 3 | 30 |
| AC-23A | 380 - 440 | 3 | 3 | 45 |
| AC-23A | 500 - 500 | 3 | 3 | 55 |
| AC-23A | 660 - 690 | 3 | 3 | 45 |
| AC-23A | 110 - 120 | 1 | 2 | 5,50 |
| AC-23A | 220 - 240 | 1 | 2 | 15 |
| AC-23A | 380 - 440 | 1 | 2 | 22 |

Max. Fuse rating IEC

| Fuse characteristic | No. of Fuses | Current (A) |
|---------------------|--------------|-------------|
| gG | 1 | 125 |

UL60947-4-1, UL508
Rated insulation voltage UI

| Voltage (V) | AC / DC |
|-------------|---------|
| 600 | AC |

Rated thermal current

| Current (A) | Ambient temperature (°C) | Additional Text |
|-------------|--------------------------|-----------------|
| 100 | 0 - 40 | - |

General Information
Text

- Listed terminal lug's type RE717 manufactured by Thomas & Betts have to be used for field wiring with single screw terminals, or equivalent.

CSA
Rated insulation voltage UI

| Voltage (V) | AC / DC |
|-------------|---------|
| 600 | AC |

Rated thermal current

| Current (A) | Ambient temperature (°C) | Additional Text |
|-------------|--------------------------|-----------------|
| 100 | 0 - 40 | - |

GENERAL TECHNICAL INFORMATION
Tightening torque of screws

| tightening torque (Nm) | tightening torque (lb-in) |
|------------------------|---------------------------|
| 4 | 35 |

Rated short-time withstand current Icw

| Time (s) | Current (A) |
|----------|-------------|
| 1 | 1300 |

Size of conductor

| composition of conductor | Min. / Max. value | No. of conductor per terminal | Cross section (mm ²) or (AWG/kcmil) | Material of the wire |
|---|-------------------|-------------------------------|---|----------------------|
| Solid wire | Min. | 1 | 2.5mm ² | Copper |
| Solid wire | Min. | 2 | 2.5mm ² | Copper |
| Flexible wire | Min. | 1 | 6mm ² | Copper |
| Flexible wire | Max. | 1 | AWG 3 | Copper |
| Flexible wire | Max. | 1 | 25mm ² | Copper |
| Flexible wire | Min. | 2 | 6mm ² | Copper |
| Single-core or stranded wire | Max. | 1 | 35mm ² | Copper |
| Single-core or stranded wire | Max. | 1 | AWG 2 | Copper |
| Flexible wire with ferrule according to DIN 46228 | Min. | 1 | 4mm ² | Copper |
| Flexible wire with ferrule according to DIN 46228 | Max. | 1 | 25mm ² | Copper |
| Flexible wire with ferrule according to DIN 46228 | Min. | 2 | 4mm ² | Copper |

Approbations
Specification
Marking

EAC



CE marking



UK Directives

IEC 60947-3; EN 60947-3; VDE 0660 Teil107

IEC 60947-3
EN 60947-3

UL 60947-4-1; CSA C22.2 No. 60947-4-1



CSA C.22.2 No.14



GB/T14048.3


Power loss per pole

Power (W)
5,80

Conditions during transport and storing

| Minimum temperature (°C) | Maximum temperature (°C) | additional requirements |
|--------------------------|--------------------------|--|
| -40 | 85 | In case of temperatures below -5°C no shock load permissible |

| Shock / Vibration | |
|-------------------------|--------------------------------------|
| Type of oscillation | Values |
| Resistance to shock | min. 5g, 30ms |
| Resistance to vibration | IEC 61373 (1999) Category 1, Class B |

General Information

- Text**
- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.
 - DC switching capacity applies to ON/OFF switches.
 - Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
 - After wiring, ALL terminal screws must be tightened to the specified torque values.
 - The protection class of the selected mounting type may vary if optional extras are used.
 - Do not lubricate or treat contacts.
 - Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.
 - Use only fully insulated cable lugs resp. FASTON receptacles.
 - After installation of the switches the spacings between the terminals must be sufficient to fulfill the requirement of the applicable standards.

| Operating temperature | | |
|-----------------------|-----------------------|-----------------------|
| | Min. Temperature [°C] | Max. Temperature [°C] |
| | -25 | 60 |